



# MOD Premium Water Filtration System

## Performance Data Sheet Commercial Modular Systems Finity MODMS11-CB20CLL,

## MODMS12-CB20CLL, MODMS13-CB20CLL

**IMPORTANT NOTICE:** Read this Performance Data Sheet and compare the capabilities of this unit with your actual water treatment needs. It is recommended that, before purchasing a water treatment unit, you have your water supply tested to determine your actual water treatment needs. These filter systems are designed to be used for the reduction of the substances listed below. Do not use where water is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system. While testing was performed under standard laboratory conditions, actual performance of these systems may vary based on local water conditions. Some or all of the contaminants reduced by these units may not be in your water supply. **See owner's manual for further instructions on filter replacement, system installation, operating procedures, and warranty. The maintenance instructions must be followed for the product to perform as indicated below.**

### General Information

These systems have been tested according to NSF/ANSI 42 for reduction of substances listed below. The concentration of the indicated substances in water entering the systems were reduced to a concentration less than or equal to the permissible limit for water leaving the system, as specified in NSF/ANSI 42. The testing was performed using spiked tap water at a flow rate of 1.7 GPM (6.4 L/min.), pH of 7.5 ± 0.5, pressure of 60 PSIG, and temperature of 68 ± 5°F.

### Maintenance

Replacement filter prices may vary. For estimated costs of replacement filters IC-20 and CB-20CLL please call toll free at 1-888-629 7839.

### Performance Claims for MODMS1x-CB20CLL (IC-20)

Substance	NSF Required Influent Challenge Concentration#/mL <sup>1</sup>	NSF Minimum Percent Reduction	Average Influent#/mL <sup>1</sup>	Avg./Max Effluent#/mL <sup>1</sup>	Avg./Min. Percent Reduction
Particulate Class III (5-to < 50 microns)	≥10,000 #/mL <sup>1</sup>	85%	32,000 #/mL	3/13 #/mL	99.9/99.9

Service Flow Rate..... 2.5 GPM (9.5 LPM)

### Performance Claims for MODMS11-CB20CLL (CB-20CLL) (1)

Substance	NSF Required Influent Challenge Concentration	NSF Minimum Percent Reduction/ Allowable Level	Average Influent	Avg./Max. Effluent	Avg./Min. Percent Reduction
Particulate Class III (5-to < 50 microns)	≥10,000 #/mL <sup>1</sup>	85%	45,000#/mL <sup>1</sup>	19/54 #/mL <sup>1</sup>	99.9/99.9
Chloramines	3.0 ± 10% mg/L <sup>2</sup>	0.5 mg/L <sup>2</sup>	3.0 mg/L <sup>2</sup>	0.06/0.44 mg/L <sup>2</sup>	98.3/85.5
Chlorine Taste and Odor	2.0 ± 10% mg/L <sup>2</sup>	1 mg/L <sup>2</sup>	2.0mg/L <sup>2</sup>	0.04/0.29 mg/L <sup>2</sup>	98.3/85.5

Service Flow Rate..... 1.7 GPM (6.4 LPM)  
Service Life..... 22,000 Gallons (83,279 Liters)

### Performance Claims for MODMS12-CB20CLL (CB-20CLL) (2)

Substance	NSF Required Influent Challenge Concentration	NSF Minimum Percent Reduction/ Allowable Level	Average Influent	Avg./Max. Effluent	Avg./Min. Percent Reduction
Particulate Class III (5-to < 50 microns)	≥10,000 #/mL <sup>1</sup>	85%	45,000#/mL <sup>1</sup>	19/54 #/mL <sup>1</sup>	99.9/99.9
Chloramines	3.0 ± 10% mg/L <sup>2</sup>	0.5 mg/L <sup>2</sup>	3.0 mg/L <sup>2</sup>	0.06/0.44 mg/L <sup>2</sup>	98.3/85.5
Chlorine Taste and Odor	2.0 ± 10% mg/L <sup>2</sup>	1 mg/L <sup>2</sup>	2.0mg/L <sup>2</sup>	0.04/0.29 mg/L <sup>2</sup>	98.3/85.5

Service Flow Rate..... 3.4 GPM (12.9 LPM)  
Service Life..... 44,000 Gallons (166,558 Liters)

### Performance Claims for MODMS13-CB20CLL (CB-20CLL) (3)

Substance	NSF Required Influent Challenge Concentration	NSF Minimum Percent Reduction/ Allowable Level	Average Influent	Avg./Max. Effluent	Avg./Min. Percent Reduction
Particulate Class III (5-to < 50 microns)	≥10,000 #/mL <sup>1</sup>	85%	45,000#/mL <sup>1</sup>	19/54 #/mL <sup>1</sup>	99.9/99.9
Chloramines	3.0 ± 10% mg/L <sup>2</sup>	0.5 mg/L <sup>2</sup>	3.0 mg/L <sup>2</sup>	0.06/0.44 mg/L <sup>2</sup>	98.3/85.5
Chlorine Taste and Odor	2.0 ± 10% mg/L <sup>2</sup>	1 mg/L <sup>2</sup>	2.0mg/L <sup>2</sup>	0.04/0.29 mg/L <sup>2</sup>	98.3/85.5

Service Flow Rate..... 5.1 GPM (19.3 LPM)  
Service Life..... 66,000 Gallons (249,837 Liters)

Pressure Range..... 10-125 psig (68.9-862 kPa/68.9-862 kPa)  
Temperature Range 35-100°F (2-38°C)

- <sup>1</sup> #/mL means Particles Per Milliliter.
- <sup>2</sup> mg/L means Milligrams Per Liter, which is equivalent to parts per million (PPM).



Systems tested and certified by NSF International against NSF/ANSI Standard 42 for Chlorine Taste and Odor Reduction, Chloramine Reduction and Particulate Reduction Class III.

Marmon Water Foodservice  
55 Railroad Ave  
West Haven, CT 06516  
1-888-629-7839

